

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 3230-0273:109 Page 1 of 1

CATEGORY: Leakage Dampers

LISTEE: United Air, PO Box 40913, Nashville TN 37204  
Contact: \*Jon Newnam (615) 256-3500

DESIGN: Models 601 and 602 leakage rated dampers. Refer to listee's data sheet for detailed product description and operational considerations.

<i>Single Section</i>				<i>Multiple Section</i>			
Width				Height			
Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.
8"	36"	8"	48"	16"	108"	8"	48"

RATING: 601: Class I-250, I-350  
602: Class II-250, II-350

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification rating and UL label.

APPROVAL: Listed as leakage-rated dampers for use in air conditioning and ventilating ducts to protect openings in fire resistive walls, partitions or floors. Suitable for vertical and horizontal installation for single section only. Multiple sections are suitable for vertical installation only.

\*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**  
*Program Manager*